

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0694:239

Page 1 of 1

CATEGORY: Photoelectric Smoke Detector

LISTEE: Fire Control Instruments, *16 Southwest Park, Westwood MA 02090
Contact: Anthony J. Shalna (781) 471-3000 FAX (781) 471-3099

DESIGN: Model MCS-Acclimate photoelectric smoke detector. Unit employs an integral supplemental heat sensor. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors when used in conjunction with listee's listed bases (CSFM Listing No. 7300-0694:194) and separately listed compatible fire alarm control units. Suitable for open areas with air velocities between 0-4000fpm.

XLF: 7272-1209:160

*Rev. 02-05-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 5, 2004**

Listing Expires June 30, 2004

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**